



590 Plant Road, PO Box 187  
Dresden, NY 14441  
www.greenidge.com

Notification Establishing Assessment Monitoring Program  
Pursuant to CCR Rule 40 CFR § 257.94(e)(3)  
Greenidge Generation LLC  
Greenidge Power Generating Station (C-Pond)  
Dresden, New York

Pursuant to 40 CFR §257.94(e)(3), an assessment monitoring program has been established at the Greenidge Generation LLC "C-Pond" coal combustion residual (CCR) regulated surface impoundment unit located at the Greenidge Generation Facility, 590 Plant Rd, Dresden, New York 14441. This is based on a statistical evaluation, completed on February 20, 2024, of groundwater data obtained from baseline monitoring activities. A statistically significant increase (SSI) over background levels for one or more constituents listed in Appendix III has been determined for the CCR unit. This statistical evaluation will be included in the annual report for 2024 to be issued in January 2025.

Greenidge Generation will complete assessment monitoring activities as required in 40 CFR §257.95.

Operating Record Placement Date: May 19, 2024